

Public Services Report

- Repair well 4 ground water metering system.
- Repair Primary generator AC unit.
- 6 after hour call outs for water leaks and breakages.
- Replace chlorine solenoid and clean the analyzer at main plant.
- Receive approved force main sewer drawings of Library.
- Clean aerator trays on 500,000 water storage tank.
- Submit application for ERU (sewer) for Library force main.
- Pave Police Station parking area.
- Patch large holes on Marylin Dr. and Holly Ave.
- Install **“Local Traffic Only”** and **“Speed Strictly Enforced”** signs on Florida Ave.